



1126 South Commerce St.  
Harlingen, TX 78550  
Off: (956) 230-3435  
Fax: (956) 720-0830  
[www.ethoseng.net](http://www.ethoseng.net)



04/02/2024

April 2, 2024

IDEA Public Schools Electrical Switchgear Upgrades at Multiple Campuses CSP#22-ESGU-0424

## **ADDENDUM NO. 4**

### **A. PURPOSE AND INTENT**

This addendum is issued for the purpose of modifying the plans for the project referenced above. This addendum shall become part of the contract and all contractors shall be bound by its content. All aspects of the specifications and drawings not covered herein shall remain the same. The General Conditions and the Special Conditions of the specifications shall govern all parts of the work and apply in full force to this addendum.

### **B. SCOPE**

#### **I. Clarification**

##### **1. Brownsville and Frontier Campus:**

- a) Switchboard Drop Over Enclosure Over NEMA 1: 316 stainless steel ventilated is acceptable.

#### **II. Specifications**

##### **1. Section 012100 - Allowances:**

- a) Schedule of Allowances: Add 3.3/A/3.

Allowance No. 3 San Benito Campus Electric Utility Pad Mount Transformer Upgrades  
\$40,000.00